

For use in the Denver Water Service Area

## **Materials Specification - 22 for CONCRETE REINFORCEMENT**

**1. MATERIAL:**

Deformed reinforcing bars shall conform to ASTM A615, Grade 40 or 60, or ASTM A617, Grade 40 or 60. Welded steel wire fabric shall conform to ASTM A185, except that the weld shear strength requirement shall be extended to include a wire size differential up to and including six gauges.

*Material Specification – 22  
Concrete Reinforcement*