

Recycled Water: (insert on plans if applicable)

1. Refer to [Chapter 11](#) of the Engineering Standards for details.
2. Recycled water lines must have a 10 foot horizontal and one foot vertical separation from sanitary sewer and potable water lines as specified in Denver Water's Engineering Standards.
3. Recycled water lines must not be placed in the same trench as sanitary sewer or potable water lines.
4. No direct cross connections between recycled water and potable water are allowed.
5. Appurtenances in vaults shall be marked as recycled water facilities in accordance with [Chapter 11](#) of Denver Water's Engineering Standards.
6. Signage must be provided stating that recycled water is in use.
7. Valves in the recycled water system shall open in a counter-clockwise direction and shall be coated with epoxy, pantone 2577U in color.
8. Manhole covers shall be pantone 2577U in color and have the words "Recycled Water" cast or molded on the top.
9. All materials used to convey recycled water must be marked as such.
10. Exposed service piping in the recycled water system, including piping inside the buildings, shall be spirally wrapped with warning tape with the words "**CAUTION: RECYCLED WATER - DO NOT DRINK.**"
11. No hose bibs are allowed on recycled water systems.