



NOTES:

1. MINIMUM COVER SHALL BE 4'-6" BELOW THE OFFICIAL STREET GRADE.
2. TRENCH SHALL CONFORM TO APPLICABLE OSHA REQUIREMENTS.
3. COMPACTION SHALL BE IN ACCORDANCE WITH CHAPTER 7.

DENVER WATER <small>1600 West 12th Avenue • Denver, Colorado 80204 Phone (303) 628-6000 • Telecopier No. (303) 628-6851</small>	
TYPICAL TRENCH SECTION	
Scale: <u> NONE </u>	Date: <u> June 2014 </u>
Drawn: <u> C.B.B. </u>	Ck: <u> K ROSS </u>
Approved: <u> [Signature] </u>	Dr. <u> 127 </u> No. <u> 35 </u>