



**NOTES:**

1. MINIMUM COVER SHALL BE 4'-6" BELOW THE OFFICIAL STREET GRADE.
2. TRENCH SHALL CONFORM TO APPLICABLE OSHA REQUIREMENTS.
3. TRENCH WIDTH SHALL NOT BE MORE THAN 36" OR LESS THAN 12" WIDER THAN THE LARGEST OUTSIDE DIAMETER OF PIPE.
4. COMPACTION SHALL BE IN ACCORDANCE WITH CHAPTER 7.

|  |                                      |
|--|--------------------------------------|
| <b>DENVER WATER</b><br><small>1600 West 12th Avenue • Denver, Colorado 80204<br/>         Phone (303) 628-6000 • Telecopier No. (303) 628-6851</small> |                                      |
| <h2 style="margin: 0;">TYPICAL TRENCH SECTION FOR<br/>PIPELINE IN DIPPING BEDROCK</h2>   |                                      |
| Scale: <u>  NONE  </u>   | Date: <u>  June 2014  </u>           |
| Drawn: <u>  C.B.B.  </u>   | Ck: <u>  K ROSS  </u>                |
| Approved: <u>  Steph C. Row  </u>  | Dr. <u>  127  </u> No. <u>  35  </u> |