



NOTE:

IDENTIFICATION MARKS ON POSTS SHALL BE 3" DIAMETER CIRCLES BROKEN IN VERTICAL CENTER () POINTING TO APPURTENANCE, WITH 1" STENCILS INSIDE CIRCLE INDICATING TYPE OF APPURTENANCE (MANHOLE, 12" GATE VALVE, 6" BLOW OFF, AIR VALVE, ETC) AND THE DISTANCE IN FEET AND INCHES FROM THE POST.

DENVER WATER 1600 West 12th Avenue • Denver, Colorado 80204 Phone (303) 628-6000 • Telecopier No. (303) 628-6851	
REFERENCE POST	
Scale: <u>NONE</u>	Date: <u>June 2014</u>
Drawn: <u>C.B.B.</u>	Ck: <u>K ROSS</u>
Approved: <u>Steph C. Ross</u>	Dr. <u>127</u> No. <u>35</u>