



NOTES:

1. A RECTANGULAR VAULT IS REQUIRED WHERE TELEMETRY OR ELECTRICAL EQUIPMENT IS ANTICIPATED TO BE INSTALLED INSIDE THE VAULT.
2. FOR A CROSS SECTION VIEW, SEE SHEET 41.
3. DO NOT PLACE SUMP DIRECTLY UNDER A MANHOLE ACCESS OPENING.
4. WHEN INSTALLING AN 8" OR SMALLER PRESSURE REGULATING VALVE ON A 20" OR SMALLER MAIN, PIPING SHALL BE THE SAME SIZE AS THE PRESSURE REGULATING VALVE & ONE PIPE SIZE SMALLER THAN THE MAIN. (LARGER SIZE CONDUIT & PRESSURE REGULATING VALVES REQUIRE APPROVAL OF LINE SIZE).

DENVER WATER <small>1600 West 12th Avenue • Denver, Colorado 80204 Phone (303) 628-6000 • Telecopier No. (303) 628-6851</small>	
PRESSURE REGULATING OR CHECK VALVE MANHOLE INSTALLATION TYPICAL PLAN	
Scale: <u> NONE </u>	Date: <u> March 2012 </u>
Drawn: <u> C.A.M. </u>	Ck: <u> K ROSS </u>
Approved: <u> [Signature] </u>	Dr. <u> 127 </u> No. <u> 35 </u>