



NOTES:

1. SEE MS-28 FOR APPROVED PRECAST CONCRETE VAULTS.
2. SEE SHEET 42 FOR PLAN AND ADDITIONAL NOTES.
3. FOR PIPE SIZES LESS THAN 12", CORP STOPS SHALL BE 1". FOR PIPE SIZES 12" AND LARGER, CORP STOPS SHALL BE 2".

DENVER WATER <small>1600 West 12th Avenue • Denver, Colorado 80204 Phone (303) 628-6000 • Telecopier No. (303) 628-6851</small>	
PRESSURE REGULATING OR CHECK VALVE RECTANGULAR VAULT TYPICAL CROSS SECTION	
Scale: <u> NONE </u>	Date: <u> June 2014 </u>
Drawn: <u> C.B.B. </u>	Ck: <u> K ROSS </u>
Approved: <u> Steph C. Ross </u>	Dr. <u> 127 </u> No. <u> 35 </u>