



**ELEVATION**

**NOTES:**

1. THIS INSTALLATION MAY BE REPLACED BY A FIRE HYDRANT WHERE APPROVED BY DENVER WATER FOR 16" AND 20" MAINS.
2. COAT PIPES, VALVES AND FITTINGS IN ACCORDANCE WITH MS-26.
3. WELD-ON OUTLETS ARE PERMISSIBLE IF QUALIFIED WELDERS AND PROCEDURES ARE USED IN ACCORDANCE WITH ANSI/AWS D11.2.

<b>DENVER WATER</b>	
1600 West 12th Avenue • Denver, Colorado 80204 Phone (303) 628-6000 • Telecopier No. (303) 628-6851	
<b>TRANSMISSION MAIN BLOWOFF INSTALLATION</b>	
Scale: <u>NONE</u>	Date: <u>June 2014</u>
Drawn: <u>C.A.M.</u>	Ck: <u>K ROSS</u>
Approved: <u>Steph C. Ross</u>	Dr. <u>127</u> No. <u>35</u>