



NOTES:

1. A WELD-ON OUTLET IS PERMISSIBLE IF A QUALIFIED WELDER AND PROCEDURES ARE USED IN ACCORDANCE WITH ANSI/AWS D11.2.
2. FOR 16" AND 20" DUCTILE IRON OR PVC PIPE.
3. COAT PIPE, VALVE AND FITTINGS IN ACCORDANCE WITH MS-26.

DENVER WATER <small>1600 West 12th Avenue • Denver, Colorado 80204 Phone (303) 628-6000 • Telecopier No. (303) 628-6851</small>	
<h2 style="margin: 0;">AIR VALVE ASSEMBLY (16" & 20" MAINS)</h2>	
Scale: <u> NONE </u>	Date: <u> June 2014 </u>
Drawn: <u> C.A.M. </u>	Ck: <u> K ROSS </u>
Approved: <u> Steph C. Row </u>	Dr. <u> 127 </u> No. <u> 35 </u>