


GENERAL NOTES:

1. CONCRETE PAD PENETRATIONS SHALL BE 1" LARGER THAN PIPE DIAMETER.
2. REFER TO LOCAL CODES & MANUFACTURER REQUIREMENTS FOR INSTALLATION INSTRUCTIONS.
3. HEATED ENCLOSURE SHALL HAVE SEPARATE APPROVED ELECTRICAL SERVICE & SHALL BE SIZED TO ALLOW ADEQUATE ROOM FOR TESTING & MAINTENANCE.
4. PIPING FOR 3" & LARGER SHALL BE DUCTILE IRON FROM THE METER TO THE BACKFLOW PREVENTION ASSEMBLY & DOWNSTREAM FROM THE BACKFLOW PREVENTION ASSEMBLY TO THE MANUFACTURER'S SETTER OR 90° BEND.

RECYCLED NOTES:

1. PIPING SHALL HAVE AN INTEGRAL PANTONE 2577U COLOR & BE EMBOSSED OR INTEGRALLY STAMPED "CAUTION: RECYCLED WATER-DO NOT DRINK."
2. THE BACKFLOW ASSEMBLY OPERATING VALVE HANDLES SHALL BE PAINTED PANTONE 2577U IN COLOR & TAGGED WITH AN INERT PLASTIC LABEL WITH BLACK PRINTING ON A WHITE FIELD READING "CAUTION: RECYCLED WATER-DO NOT DRINK."
3. ENCLOSURES SHALL BE IDENTIFIED WITH SIGNAGE "RECYCLED WATER USED FOR IRRIGATION-DO NOT DRINK" ON THE ACCESS DOOR.

 <p>DENVER WATER 1600 West 12th Avenue • Denver, Colorado 80204 Phone (303) 628-6000 • Telecopier No. (303) 628-6851</p>	
<p>OUTSIDE SETTING FOR 3" & LARGER REDUCED PRESSURE PRINCIPLE ASSEMBLY N-TYPE, ABOVE GROUND</p>	
Scale: <u> NONE </u>	Date: <u> February 2013 </u>
Drawn: <u> C.A.M. </u>	Ck: <u> K ROSS </u>
Approved: <u> <i>John H. Binkley</i> </u>	Dr. <u> 127 </u> No. <u> 35 </u>