



NOTES:

1. BENDING COPPER RISERS FOR GRADE ADJUSTMENT OF THE METER YOKE IS NOT PERMITTED.
2. SERVICE LINES SHALL NOT CROSS IN THE METER PIT.
3. COPPER RISERS SHALL BE NEW. DAMAGED OR BENT COPPER RISERS ARE NOT PERMITTED.
4. INSTALL METER PIT AND SERVICE LINE IN ACCORDANCE WITH SPECIFICATION SECTION 33 19 13.
5. INSTALL IN LANDSCAPED AREAS ONLY.

DRAWN BY: <i>BAIRES</i>
CHKD BY: <i>K ROSS/</i>
APPD BY:
ORIGINATION DATE: <i>JANUARY 2021</i>
REVISION DATE:

33269
OUTSIDE SETTING
FOR 3/4" & 1" METER

D DENVER WATER

1600 West 12th Ave
 Denver, Colorado 80204-3412
 T: 303.628.6000
 F: 303.628.6851
 denverwater.org