

Material Specification – 22

CONCRETE REINFORCEMENT

1. GENERAL

Deformed reinforcing bars shall be in accordance with ASTM A 615, Grade 40 or 60. Welded steel wire fabric shall be in accordance with ASTM A 185, except that the weld shear strength requirement shall be extended to include a wire size differential up to and including 6 gauges.

*Material Specification – 22
Concrete Reinforcement*