

Material Specification – 24

WATER SERVICE LINE PIPE

1. GENERAL

Water service line pipe shall be manufactured in accordance ASTM B 88 with the following additional requirements or exceptions.

2. SIZES

This Specification covers water service line pipe in 3/4-inch, 1-inch, 1 1/4-inch, 1 1/2-inch, and 2-inch nominal diameters.

3. PIPE MATERIAL

Water service line pipe shall be seamless copper water tube in accordance with ASTM B 88, furnished in coils, annealed, Type K Copper UNS No. 12200.

4. QUALITY CONTROL

The Manufacturer shall submit a written statement that the inspection and all specified tests have been completed and that results comply with the requirements of these Standards. Components in contact with potable water shall be certified to comply with NSF/ANSI 61, and a copy of the NSF/ANSI 61 certification shall be provided to Denver Water, if requested.

5. PLACE OF MANUFACTURE

Water service line pipe installed in the City and County of Denver and Total Service Contract Areas shall be manufactured domestically.

6. APPROVED MANUFACTURERS

Cambridge-Lee Industries
Cerro Flow Products
CMC Howell Metal
Mueller Industries
Wieland Copper

*Material Specification – 24
Water Service Line Pipe*