



NOTES:

1. A WELD-ON OUTLET IS PERMISSIBLE IF A QUALIFIED WELDER AND PROCEDURES ARE USED BY THE PIPE MANUFACTURER IN ACCORDANCE WITH ANSI/AWS D11.2.
2. COAT PIPE, VALVE AND FITTINGS IN ACCORDANCE WITH MS-26.



**SINGLE AIR VALVE ASSEMBLY
(16" & 20" DUCTILE IRON MAINS)**

Scale: NONE Date: May 2018

Drawn: RLB Ck: K ROSS

Approved: Steph C. Rem Dr. 127 No. 35