



**NOTES:**

1. A WELD-ON OUTLET IS PERMISSIBLE IF A QUALIFIED WELDER AND PROCEDURES ARE USED BY THE PIPE MANUFACTURER IN ACCORDANCE WITH ANSI/AWS D11.2.
2. COAT PIPE, VALVE AND FITTINGS IN ACCORDANCE WITH MS-26.



**DOUBLE AIR VALVE ASSEMBLY  
(16" & 20" DUCTILE IRON MAINS)**

Scale: <u>  NONE  </u>	Date: <u>  May 2018  </u>
Drawn: <u>  RLB  </u>	Ck: <u>  K ROSS  </u>
Approved: <u>  Stephen C. Pean  </u>	Dr. <u>  127  </u> No. <u>  35  </u>