



NOTES:

1. A RECTANGULAR VAULT IS REQUIRED WHEN TELEMETRY OR ELECTRICAL EQUIPMENT IS TO BE INSTALLED INSIDE THE VAULT, SEE SHEET 30.
2. SEE SHEET 33 FOR TYPICAL SECTION.
3. DO NOT PLACE SUMP DIRECTLY UNDER THE MANHOLE ACCESS OPENING.
4. WHEN INSTALLING AN 8-INCH OR SMALLER PRESSURE REGULATING VALVE ON A 20-INCH OR SMALLER MAIN, PIPING SHALL BE THE SAME SIZE AS THE PRESSURE REGULATING VALVE AND ONE PIPE SIZE SMALLER THAN THE MAIN. (LARGER SIZE CONDUIT AND PRESSURE REGULATING VALVES REQUIRE APPROVAL OF LINE SIZE).
5. FOR PIPE SIZES LESS THAN 12-INCHES, CORP STOPS SHALL BE 1-INCH. FOR PIPE SIZES 16 & 20-INCH, CORP STOPS SHALL BE 2-INCH.

**OPTIONAL RESTRAINED
DISMANTLING JOINT**

D DENVER WATER	
PRESSURE REGULATING VALVE MANHOLE INSTALLATION TYPICAL PLAN	
Scale: <u> NONE </u>	Date: <u> May 2018 </u>
Drawn: <u> RLB </u>	Ck: <u> K ROSS </u>
Approved: <u> Steph C. Rev </u>	Dr. <u> 127 </u> No. <u> 35 </u>