



**NOTES:**

1. THIS INSTALLATION MAY BE REPLACED BY A FIRE HYDRANT WHERE APPROVED BY DENVER WATER FOR 16-INCH AND 20-INCH MAINS.
2. COAT PIPES, VALVES AND FITTINGS IN ACCORDANCE WITH MS-26.
3. WELD-ON OUTLETS ARE PERMISSIBLE IF QUALIFIED WELDERS AND PROCEDURES ARE USED BY THE PIPE MANUFACTURER IN ACCORDANCE WITH ANSI/AWS D11.2.



**TRANSMISSION MAIN BLOWOFF  
INSTALLATION**

Scale: <u>  NONE  </u>	Date: <u>  May 2018  </u>
Drawn: <u>  RLB  </u>	Ck: <u>  K ROSS  </u>
Approved: <u>  [Signature]  </u>	Dr. <u>  127  </u> No. <u>  35  </u>