



NOTES:

1. NUT MATERIAL SHALL BE CAST IRON IN ACCORDANCE WITH ASTM A 126 CLASS B OR DUCTILE IRON IN ACCORDANCE WITH ASTM A 536.
2. HOLE THROUGH NUT TO MATCH VALVE ACTUATOR SHAFT OR VALVE STEM EXTENSION. HOLE SHOWN FITS VALVE OPERATOR EXTENSION ON SHEET 44.
3. NUT SHALL BE COATED WITH FUSION-BONDED EPOXY, OR LIQUID EPOXY, MINIMUM 16 MIL DFT IN ACCORDANCE WITH AWWA C210, FEDERAL COLOR NO 2577U.
4. AN ARROW AND THE WORD OPEN SHALL BE CAST ON THE FLANGE BASE TO INDICATE DIRECTION OF OPENING IN ACCORDANCE WITH AWWA C509.

DENVER WATER	
RECYCLED WATER SYSTEM PENTAGON OPERATING NUT	
Scale: <u> NONE </u> _ _ _	Date: <u> May 2018 </u> _ _
Drawn: <u> RLB </u> _ _ _	Ck: <u> K ROSS </u> <u> KLR </u>
Approved: <u> [Signature] </u> _ _ _	Dr. <u> 127 </u> No. <u> 35 </u> _ _