



ERRATA 2

NOTES:

1. BENDING COPPER RISERS FOR GRADE ADJUSTMENT OF THE METER YOKE IS NOT PERMITTED.
2. SERVICE LINES SHALL NOT CROSS IN THE METER PIT.
3. COPPER RISERS SHALL BE NEW. DAMAGED OR BENT COPPER RISERS ARE NOT PERMITTED.
4. INSTALL METER PIT AND SERVICE LINE IN ACCORDANCE WITH SPECIFICATION SECTION 3.02.
5. COMPOSITE METER PITS SHALL BE LOCATED IN LANDSCAPED AREAS ONLY NOT SUBJECT TO TRAFFIC LOADING.

<b>D DENVER WATER</b>	
<b>OUTSIDE SETTING FOR 3/4" &amp; 1" METER</b>	
Scale: <u>  NONE  </u>	Date: <u>  January 2020  </u>
Drawn: <u>  RLB  </u>	Ck: <u>  K ROSS  </u>
Approved: <u>  <i>[Signature]</i>  </u>	Dr. <u>  127  </u> No. <u>  35  </u>