



GENERAL NOTES:

1. CONCRETE PAD PENETRATIONS SHALL BE 1-INCH LARGER THAN PIPE DIAMETER.
2. REFER TO LOCAL CODES AND MANUFACTURER REQUIREMENTS FOR INSTALLATION INSTRUCTIONS.
3. HEATED ENCLOSURE SHALL HAVE SEPARATE APPROVED ELECTRICAL SERVICE AND SHALL BE SIZED TO ALLOW ADEQUATE ROOM FOR TESTING AND MAINTENANCE.
4. PIPING FOR 3-INCH AND LARGER SHALL BE DUCTILE IRON FROM THE METER TO THE BACKFLOW PREVENTION ASSEMBLY AND DOWNSTREAM FROM THE BACKFLOW PREVENTION ASSEMBLY TO THE MANUFACTURER'S SETTER OR 90° BEND.

RECYCLED NOTES:

1. PIPING SHALL HAVE AN INTEGRAL PANTONE 2577U COLOR AND BE EMBOSSED OR INTEGRALLY STAMPED "CAUTION: RECYCLED WATER-DO NOT DRINK."
2. THE BACKFLOW ASSEMBLY OPERATING VALVE HANDLES SHALL BE PAINTED PANTONE 2577U IN COLOR AND TAGGED WITH AN INERT PLASTIC LABEL WITH BLACK PRINTING ON A WHITE FIELD READING "CAUTION: RECYCLED WATER-DO NOT DRINK."
3. ENCLOSURES SHALL BE IDENTIFIED WITH SIGNAGE "RECYCLED WATER USED FOR IRRIGATION-DO NOT DRINK" ON THE ACCESS DOOR.



OUTSIDE SETTING FOR 3" & LARGER REDUCED PRESSURE PRINCIPLE ASSEMBLY N-TYPE, ABOVE GROUND

Scale: <u> NONE </u>	Date: <u> May 2018 </u>
Drawn: <u> RLB </u>	Ck: <u> K ROSS </u>
Approved: <u> Steph C. Pen </u>	Dr. <u> 127 </u> No. <u> 35 </u>