



**NOTES:**

1. VAULT PENETRATIONS SHALL BE 1-INCH LARGER THAN PIPE OUTSIDE DIAMETER.
2. DOUBLE CHECK BACKFLOW PREVENTION ASSEMBLY SHALL BE LOCATED IN LANDSCAPED AREAS.
3. TOTAL COPPER TUBING LENGTH MEASURED FROM MAIN TO METER TO DOUBLE CHECK BACKFLOW PREVENTION ASSEMBLY TO DRINKING FOUNTAIN SHALL HAVE A MAXIMUM LENGTH OF 250- FEET.
4. REFER TO LOCAL CODES AND MANUFACTURER REQUIREMENTS FOR INSTALLATION INSTRUCTIONS.

<b>DRINKING FOUNTAIN DOUBLE CHECK VALVE BELOW GROUND INSTALLATION</b>	
Scale: <u>  NONE  </u>	Date: <u>  May 2018  </u>
Drawn: <u>  RLB  </u>	Ck: <u>  K ROSS  </u>
Approved: <u>  Steph C. Ross  </u>	Dr. <u>  127  </u> No. <u>  35  </u>