


DETAIL 1
THIS SHT



IDENTIFICATION
EXAMPLE

NOTE:
IDENTIFICATION MARKS ON POSTS SHALL BE 3-INCH DIAMETER CIRCLES BROKEN IN VERTICAL CENTER () POINTING TO APPURTENANCE, WITH 1-INCH STENCILS INSIDE CIRCLE INDICATING TYPE OF APPURTENANCE (MANHOLE, 12-INCH GATE VALVE, 6-INCH BLOW OFF, AIR VALVE, ETC) AND THE DISTANCE IN FEET AND INCHES FROM THE POST.

D DENVER WATER	
REFERENCE POST	
Scale: <u> NONE </u>	Date: <u> May 2018 </u>
Drawn: <u> RLB </u>	Ck: <u> K ROSS </u>
Approved: <u> [Signature] </u>	Dr. <u> 127 </u> No. <u> 35 </u>