



ERRATA 2

NOTES:

1. BENDING COPPER RISERS FOR GRADE ADJUSTMENT OF THE METER YOKE SHALL NOT BE PERMITTED.
2. SERVICE LINES SHALL NOT CROSS IN THE METER PIT.
3. COPPER RISERS SHALL BE NEW. DAMAGED OR BENT COPPER RISERS ARE NOT PERMITTED.
4. CONCRETE METER PIT REQUIRED.
5. METER PIT LID FOR INSTALLATIONS SUBJECT TO TRAFFIC LOADING WITH WRITTEN APPROVAL BY DENVER WATER.



MANHOLE RING AND COVER
OVER METER PIT

Scale: NONE Date: January 2020

Drawn: RLB Ck: K ROSS

Approved: *[Signature]* Dr. 127 No. 35