



NOTES:

1. MINIMUM COVER SHALL BE 4--FEET 6--INCHES BELOW THE GROUND LINE.
2. TRENCH SHALL CONFORM TO APPLICABLE OSHA REQUIREMENTS.
3. TRENCH WIDTH SHALL NOT BE MORE THAN 36--INCHES OR LESS THAN 12--INCHES WIDER THAN THE LARGEST OUTSIDE DIAMETER OF PIPE.
4. COMPACTION SHALL BE IN ACCORDANCE WITH CHAPTER 7.

D DENVER WATER	
TYPICAL TRENCH SECTION FOR PIPELINE IN DIPPING BEDROCK	
Scale: <u> NONE </u>	Date: <u> May 2018 </u>
Drawn: <u> RLB </u>	Ck: <u> K ROSS </u>
Approved: <u> [Signature] </u>	Dr. <u> 127 </u> No. <u> 35 </u>